

Summary Children's Corner 475 South Street - Morristown

Date	Sample Location	Lead		Copper		Lab
		Action Level (mg/L)	Result (mg/L)	Action Level (mg/L)	Result (mg/L)	
3/11/2020	Handwashing 30	0.015	ND	1.3	0.330	Aqua Pro-Tech
	Bathroom 29	0.015	0.0796	1.3	4.120	
	Kitchenette 29/30	0.015	ND	1.3	0.391	
	Bathroom 27	0.015	ND	1.3	0.416	
	Kitchenette 27/28	0.015	ND	1.3	0.336	
	Handwashing 28	0.015	ND	1.3	0.340	
	Kitchenette 24/25	0.015	ND	1.3	0.387	
	Handwashing 24	0.015	ND	1.3	0.242	
	Kitchenette 21/22	0.015	0.0212	1.3	1.200	
	Bathroom 21/22	0.015	0.00229	1.3	0.416	
	Bathroom 18/19	0.015	ND	1.3	0.321	
	Kitchenette 16/17	0.015	0.00946	1.3	0.351	
	Kitchenette 19/18	0.015	ND	1.3	0.358	
	Bathroom 18	0.015	ND	1.3	0.281	
	Bathroom 17	0.015	ND	1.3	0.303	
	Bathroom 16/17	0.015	ND	1.3	0.581	
	Staff Lounge 13A	0.015	ND	1.3	0.438	
	Staff Bathroom 13A	0.015	0.213	1.3	1.840	
	Kitchen 3	0.015	ND	1.3	0.342	
	Kitchen 2	0.015	ND	1.3	0.421	
	Kitchen 1 (single sink)	0.015	0.0229	1.3	0.260	
Staff Bath Female 006	0.015	0.025	1.3	0.809		
Staff Bath Male 005	0.015	0.106	1.3	1.590		
Lactation Rm 009	0.015	ND	1.3	0.349		
Sick Kids Bathroom 004	0.015	0.0399	1.3	0.769		
Field Blank	0.015	ND	1.3	ND		
4/30/2020	Bathroom 29	0.015	ND	1.3	0.019	SGS
	Kitchenette 21/22	0.015	ND	1.3	0.046	
	Staff Bathroom 13A	0.015	ND	1.3	0.010	
	Kitchen 1 (single sink)	0.015	0.00201	1.3	0.020	
	Staff Bath Female 006	0.015	ND	1.3	0.013	
	Staff Bath Male 005	0.015	ND	1.3	ND	
	Sick Kids Bathroom 004	0.015	ND	1.3	0.010	